CITY OF SAN CLEMENTE GENERAL NOTES FOR SEWER SYSTEMS

- 1. ALL WORK SHALL CONFORM TO THE STANDARD PLANS AND SPECIFICATIONS OF THE CITY OF SAN CLEMENTE, ORANGE COUNTY PUBLIC FACILITIES & RESOURCES DEPARTMENT (PF&RD), AND STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION, LATEST EDITION. ALL WORK SHALL BE SUBJECT TO THE CITY ENGINEER'S ACCEPTANCE AS A CONDITION OF COMPLETION OF WORK BY THE CONTRACTOR.
- 2. THE CONTRACTOR SHALL NOTIFY THE CITY OF SAN CLEMENTE'S INSPECTOR AT LEAST 48 HOURS PRIOR TO ANY CONSTRUCTION AT (949) 361-6131.
- 3. ALL WATER AND SEWERAGE FACILITIES SHALL CONFORM TO THE CITY'S "STANDARD PROVISIONS AND STANDARD DRAWINGS FOR THE CONSTRUCTION OF WATER AND SEWERAGE FACILITIES", LATEST EDITION, HEREIN REFERRED AS THE "CITY WATER AND SEWER STANDARDS". THE CONTRACTOR SHALL HAVE A COPY OF APPROVED PLANS, PERMITS AND THE WATER AND SEWER STANDARDS ON THE JOB AT ALL TIMES.
- 4. FACILITIES NOT IN DEDICATED CITY RIGHT OF WAY SHALL NOT BE CONNECTED TO A PUBLIC FACILITY UNTIL THE CITY HAS ACCEPTED AND RECORDED AN EASEMENT FOR THE FACILITIES. A COPY OF THE RECORDED EASEMENT SHALL BE PROVIDED TO THE INSPECTOR PRIOR TO ANY CONNECTION BEING MADE IN THE FIELD.
- 5. CONNECTION TO EXISTING MANHOLE, WHERE STUBS DO NOT EXIST, SHALL BE DONE BY CORE DRILLING.
- 6. WORK NOT DONE IN THE PRESENCE OF THE CITY INSPECTOR IS SUBJECT TO REJECTION.
- 7. THE CONTRACTOR SHALL REMOVE OR ABANDON ALL UNUSED WATER AND SEWERAGE FACILITIES PER THE WATER AND SEWER STANDARDS.
- 8. THE SEWER MAIN SHALL BE BALLED, CLEANED AND TESTED PRIOR TO ACCEPTANCE BY THE CITY. FINAL BALLING AND TESTING TO BE DONE IN THE PRESENCE OF THE CITY INSPECTOR AFTER APPROPRIATE WORK IS COMPLETE AND STREET HAS BEEN PAVED AND MANHOLES RAISED TO GRADE.
- 9. MINIMUM SEWER COVER SHALL BE 6 FEET BELOW SUBGRADE. IF, DURING CONSTRUCTION, SEWER IS FOUND TO HAVE LESS THAN 6 FEET OF COVER, SEWER SHALL BE ENCASED IN CONCRETE.
- 10. ALL LATERAL LOCATIONS SHALL BE CLEARLY MARKED WITH A 2 INCH HIGH "S" CHISLED IN THE CURB FACE BY THE CONTRACTOR.
- 11. STATIONS SHOWN THUS 0+00 AS SHOWN ON THE PLAN AND PROFILE ARE SEWER STATIONS AND ARE INDEPENDENT OF STREET STATIONS AND ARE STATIONS ALONG CENTERLINE OF SEWER FROM DOWNSTREAM MANHOLE.
- 12. SEWER LINE DISTANCE SHOWN IN PROFILE IS THE HORIZONTAL DISTANCE MEASURED BETWEEN MANHOLES.

Revised 7/31/2002 Page 1 of